



GOVERNMENT OF KARNATAKA

Office of the District Fire Officer

Karnataka State Fire Service

Fire Station

BAGALKOT-587 102

Date 25/09/2026

C.NO/ 854 /ADV/DFO/BAGALKOT/2026

To,

Principal

Nehru International Public School,

Guledgudd, Dist-Bagalkot .

Sir,

Sub : Issue of 'Fire safety recommendation/Advice' to Shree Hole-Hucheshwar Shikshana and Grameen Abhirudhi Samsthe ® Guledgudd. Nehru International Public School, Sy No : 59/2, Guledgudd, Bagalkot District.

Ref: 1) Applicant request letter Dated : 18/09/2026.
2) No.GBC(2)044/2020-21 Dated : 18/06/2022 S.O No.156-B.
3) GBC(2)2108/2025. E-Office Com No 82041. Dated : 03/02/2026

**_*_*_*_*_*_

With reference to the subject above cited, the premises of Nehru International Public School, building consisting with 02 Block, each block with Ground floor + 02 Upper floor situated at Sy No : 59/2, Guledgudd, Bagalkot District. was inspected by me on 18/09/2026 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and submitted the details as under. Vide ref (3).

ANNEXURE-1

(Up to 14.99 mtrs. in height)

Group B Education Building

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	Principal Nehru International Public School, Guledgudd, Dist-Bagalkot
02	Name and Address of the premises.	:	Shree Hole-Hucheshwar Shikshana and Grameen Abhirudhi Samsthe ® Guledgudd. Nehru International Public School, Sy No : 59/2, Guledgudd, Bagalkot District
03	Name and address of the Building owner	:	President Shree Hole-Hucheshwar Shikshana and Grameen Abhirudhi Samsthe ® Guledgudd
04	Number of buildings	:	01 Building
05	Number of floors	:	Block-1 Ground+02 upper floors Block-2 Ground+02 upper floors
06	Floor-wise details of occupancy	:	Block - 1 Ground Floor : Class Room-14, Toilet section.

	First Floor	:	Class Room-14.	
	Second Floor	:	Class Room-14.	
	Block - 2 Ground Floor	:	Class Room-11, Toilet section.	
	First Floor	:	Class Room-11.	
	Second Floor	:	Class Room-11.	
		:	Each Block 11.00 Mtrs	
07	Height of the building	:	6358.50 Sq Mtrs.	
08	Site area		Block-1	Block-2
09	Built-up area of each floor:-	:	720.00 Sq. Mtrs.	405.00 Sq. Mtrs.
	Ground Floor	:	720.00 Sq. Mtrs.	405.00 Sq. Mtrs.
	First Floor	:	720.00 Sq. Mtrs.	405.00 Sq. Mtrs.
	Second Floor	:	2160.00 Sq. Mtrs.	1215.00 Sq Mtrs.
10.	Total built-up area		Block-1	Block-2
11.	Surrounding properties:-	:	Road (09 Mtr wide)	Road (09 Mtr wide)
	East	:	Agriculture Land	Agriculture Land
	West	:	Block - 2	Agriculture Land
	North	:	Agriculture Land	Block - 1.
	South	:		
12.	Set-back area available around the building :-		Block-1	Block-2
	East	:	06.00 Mtrs.	06.00 Mtrs.
	West	:	07.00 Mtrs.	07.00 Mtrs.
	North	:	05.00 Mtrs.	06.00 Mtrs
	South	:	06.00 Mtrs.	05.00 Mtrs.
	Allowed setbacks (open space) should be maintained free from further obstruction / construction			

Note :Recommended to provide and maintain setbacks as per Local ZR.

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)																		
01.	Accessibility to the premises	The premise is abutting by 09.00 mtrs. Wide hard surfaced road located on Eastern side.	Adequate																		
02.	No. of entrances	01 No entrance/ exit of 05.00 mtrs wide is provided.	Minimum 06 Mtr width provided																		
03.	No. of staircases available	<table><tr><td>Nos. of staircases</td><td>:</td><td>02+02</td></tr><tr><td>Width of staircases</td><td>:</td><td>1.20 mt</td></tr><tr><td>Width of treads</td><td>:</td><td>30 cm</td></tr><tr><td>Height of risers</td><td>:</td><td>15 cm</td></tr><tr><td>Nos. of riser per flight</td><td>:</td><td>15 no.</td></tr><tr><td>Height of handrails</td><td>:</td><td>0.90 mt</td></tr></table>	Nos. of staircases	:	02+02	Width of staircases	:	1.20 mt	Width of treads	:	30 cm	Height of risers	:	15 cm	Nos. of riser per flight	:	15 no.	Height of handrails	:	0.90 mt	Recommended to provide staircases maintaining travel distance with 22.50 mtrs. With minimum 02.00 mtrs. Width, 30 cm treads width, 15 cm treads height, 1 mtr. Handrail, with minimum 02.20 head room
Nos. of staircases	:	02+02																			
Width of staircases	:	1.20 mt																			
Width of treads	:	30 cm																			
Height of risers	:	15 cm																			
Nos. of riser per flight	:	15 no.																			
Height of handrails	:	0.90 mt																			

		Head Room clearance	:	2.20 mtr	clearance.
04.	Lifts & Capacity	No of Lifts	:	--	N/A
		Capacity	:	--	
05.	Portable Fire extinguishers	Not Provided			A. One ABC type extinguisher of 6 KG capacity for every 100 m². B. One CO₂ extinguisher of 4.5 KG Capacity shall be provided near electrical panel board. C. All Extinguisher suggested above should be with BIS markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically.
06.	Hose reel hose system	Not Provided			One Hose reel hose required for every 1000 m ² of built-up area and G.I pipe of minimum 63 mm shall be provided. Hose reel hose of minimum 19 mm size of adequate length to reach the farthest point should be provided near the staircase at each floor with a shut off branch having a nozzle of 5 mm size.
07.	Pump at the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Not Provided			The system should be connected to a booster pump of 450 LPM or of 5 HP capacities.
08.	Diesel Generator	Not Provided			Diesel generator of 15 KVA capacities should be provided to supply alternative power supply.
09.	Terrace tank over respective tower terrace.	Not provided			The system should be connected to an overhead tank of 5,000 ltrs. Capacity.
10.	Escape routes	Not Marked			Recommended to Provide Direction in which the employees/ Students should have to move in the event of any emergency have been marked with luminous paint at each floor directing the employees towards emergency exits
11.	Fire order	Not Displayed			Fire safety plans should be

	(Fire safety plans)		indicated with details of actions to be taken in case of an emergency near staircase landings at each floor with telephone numbers of Badami fire station i.e. 08357-221101 & 101 telephone numbers of the nearest Ambulance service & Police Station.
12.	No smoking board	Not Displayed	COPTA Sec-4 direction No Smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry/exit of the each floor.
13.	Fire Siren	Not installed	A Fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.
14.	Nominate of Fire Nodal Officer	Not Nominated	A Fire Nodal Officer shall be nominated either from teaching or non teaching staff.
15.	Fire fighting training	02 No of Staffs are trained	At-least 40% of employees shall be got trained in basic fire fighting at R.A.Mundkur fire & Emergency Services Academy, Bannerughatta road, Bangalore within 3 months or at an early date. And shall be submitted to this office.
16.	Electrical installation	----	Recommended to provide all Electrical cable on Terminal point in the electrical panel and distribution boxes should be coated with certified transparent fire retardant coat.
17.	Fire precautionary measures:- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B. Accumulation of combustible waste in and around the premises should be avoided. C. The exit ways shall be always kept clear without any obstruction. D. Liquefied petroleum gas should not be stored in the building. E. The doors shall not be kept locked/latched during working hours and shall be free from		

obstruction.

- F. During the class hours the class room doors shall not be locked from inside to outside.
- G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire And Emergency Service Department is issuing "Fire Safety Recommendation" to Shree Hole-Hucheshwar Shikshana and Grameen Abhirudhi Samsthe ® Guledgudd. Nehru International Public School, Sy No : 59/2, Guledgudd, Bagalkot District Subject to condition and compliance of the above recommendations in column 4 of serial B within 03 months compliance to the undersigned.


♣ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life safety will have to be complied with mandatorily.

From the above details it is clear that the 'Management' of the above Educational building have been recommended to provide fire precautionary measures as per National Building Code 2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2. After full-filling the above recommendations, a Certificate should be obtained by this office. If at any time any of the conditions are found not complied with, this Certificate shall stand withdrawn/cancelled.

The "Fire Safety Recommendation" is valid for a period of one year from the date of issue and it is renewable.



Your's Faithfully


District Fire Officer,
Fire Station
BAGALKOT-587 102